

# EN 15154-4:2009 Emergency safety showers

## – Part 4: Non plumbed-in eyewash units

### Statement of Conformance

---

We hereby declare that the following products

- Plum Eyewash
- Plum Eyewash Duo
- Plum pH Neutral
- Plum pH Neutral Duo

meet *EN 15154-4:2009 Emergency safety showers – Part 4: Non plumbed-in eyewash units* as follows with regard to the requirements of this standard

<b>Performance requirements</b>	
4.1. Efficacy	Conforming
4.2 Quality of the rinsing fluid	
4.2.1 General	Conforming
4.2.2 Water	Water Highly Purified, Ph.Eur
4.2.3 Solutions	Conforming
4.3 Flow	Conforming
4.4 Container for rinsing fluid	
4.4.1 General	Conforming
4.4.2 Transportable eyewash units	Not applicable
4.4.3 Portable eyewash units	Volume 200 ml, 500 ml or 1000 ml
4.4.4 Personal eyewash units	Volume 200 ml, 500 ml or 1000 ml Belt bag available for 200 ml bottles
<b>Functional requirements</b>	
5.1 General	Conforming
5.2 Single use eyewash units	Conforming
5.3 Multiple use eyewash units	Not applicable
5.4 Reconditionable eyewash units	Not applicable
<b>Information for use</b>	
6.1 Labelling and marking	Conforming
6.2 Further information and guidance for use	Not applicable with regard to safe use of the product.

More information and guidance is available on our website [www.plum.eu](http://www.plum.eu)